

**TAMIL NADU FIRE & RESCUE SERVICES**  
**NO OBJECTION CERTIFICATE**  
**FOR SCHOOL**

**SL.NO:11/2024**

**No: 107/V/2024**

**DATE: 02.03.2024**


**Sub: Fire & Rescue Service – Fire & Rescue Station – Triplicane**  
**Issuing No Objection Certificate to start school to issue**  
**Approval regarding.**

**Ref: 1. Govt. Order No.206. School Education (Primary Education 2 (2))**  
**2. Application receiving date: 01/03/2024**  
**Reference cited, Govt. order & as per the applications.**

**Door: NO:97/46,V.M.STREET,ROYAPETTAH,CHENNAI-14.** Established in above address **M/S: GILL ADARSH SCHOOL** they said above School inspected by R.MURUGESAN. SSO, Fire & Rescue Station Triplicane Date on.01/03/2024 The following Govt. norms should be fulfilled by school authority. This NOC valid for ONE Year from the date of issue.

**SAFETY MEASURES**

- (A) This license is valid for one year from the date of issue,
- (B) Fire safety systems should be maintained in good working condition.
- (C) Mock drill to be conducted periodically with the help of local fire brigade.
- (D) Any erection of permanent or temporary structure should be intimated to this department.
- (E) A trained fire service person, preferably retired on should be appointed.
- (F) Further to limit the occupant load and to ensure better fire and life safety measures the following additional measures are insisted.
- (G) Building occupancy capacity should not be more than 4 people per sq.metre as per the national building code 2005.
- (H) The staircase treads and flooring shall be treated with rough finish (grooving) to avoid falling of children.
- (I) As per Para 6.3 of the BIS standards: 1997 as the classrooms have only one entrance, the capacity of the class room shall have to be limited to 45 students.
- (J) Periodical maintenance and care should be taken to maintain all fire protection equipment.
- (K) Mock drill has to be conducted at regular intervals in consultation with the division officer, fire & rescue service, Chennai central division at kilpauk.



**TO, THE PRINCIPAL,**  
**M/S: GILL ADARSH SCHOOL,**  
**NO: 97/46, V.M.STREET,**  
**CHENNAI-14.**

*சிறப்பு நிலைய அலுவலர்*  
*02/03/24*  
**தீயணைப்பு மற்றும் மீட்புப்பணிகள் நிலையம்**  
**திருவல்லிக்கேணி, சென்னை-600 002**

Copy: District Officer, Chennai Central District.